

Facility Summary in Gallatin County in the City of Belgrade

Location: BELGRADE CARD LOCK
163 Thunder Rd
Belgrade, MT 59714-8939 Gallatin

System Facility ID:56-14162

Facility Code: 30793
Last Inspected On: 10/08/2020
Operating Permit Renewal Date: 03/16/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Parkland USA Corporation	7018521194
Operator Contact:	Calvin Wilson;Jason Shanley	

Owner/Operator: Parkland USA Corporation

Caleb Jensen, UST Class B Operator
Calvin Wilson, UST Class A Operator
Calvin Wilson, UST Class B Global Operator
Jason Shanley, UST Class A Operator
Jason Shanley, UST Class B Global Operator
Kelly Shutes, UST Class B Global Operator

Tank Code	01	Tank Age	17	Tank Installed Date	09/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4999	Spill Test Date	10/08/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/08/2020	Line Tightness Test Date	11/29/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/23/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				
Tank Code	02	Tank Age	17	Tank Installed Date	09/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5000	Spill Test Date	10/08/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	20000	ATG Test Date	10/08/2020	Line Tightness Test Date	09/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/23/2020			ATG Type	Gilbarco/EMC Basic;Veeder Root/				
Tank Code	03	Tank Age	17	Tank Installed Date	09/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5001	Spill Test Date	10/08/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	10/08/2020	Line Tightness Test Date	10/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/23/2020			ATG Type	Gilbarco/EMC Basic;Veeder Root/				
Tank Code	04	Tank Age	17	Tank Installed Date	09/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5002	Spill Test Date	10/08/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/08/2020	Line Tightness Test Date	09/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/23/2020			ATG Type	Gilbarco/EMC Basic;Veeder Root/				
Tank Code	05	Tank Age	17	Tank Installed Date	09/16/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5003	Spill Test Date	10/08/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/08/2020	Line Tightness Test Date	09/18/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/23/2020			ATG Type	Gilbarco/EMC Basic;Veeder Root/				

Tank Code	06	Tank Age	17	Tank Installed Date	09/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5004	Spill Test Date	10/08/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	10/08/2020	Line Tightness Test Date	09/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/23/2020			ATG Type	Gilbarco/EMC Basic;Veeder Root/				
Tank Code	07	Tank Age	17	Tank Installed Date	09/05/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5063	Spill Test Date	10/08/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	10/08/2020	Line Tightness Test Date	09/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/23/2020			ATG Type	Gilbarco/EMC Basic;Veeder Root/				

Facility Summary in Gallatin County in the City of Belgrade

Location: CENTRAL COPTERS
395 Jetway Dr
Belgrade, MT 59714 Gallatin

System Facility ID:60-15232

Facility Code: 30949
Last Inspected On: 05/05/2022
Operating Permit Renewal Date: 08/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Central Copters4065869185

Operator Contact: Brian Geary;Mark Duffy4065869185

Owner/Operator: Central Copters

Brian Geary, UST Class A Operator
Brian Geary, UST Class B Operator
Mark Duffy, UST Class A Operator

Mark Duffy, UST Class B Operator

Tank Code	01	Tank Age	6	Tank Installed Date	03/01/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5547	Spill Test Date	05/05/2022	Piping Installed Date	10/14/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/24/2022	Sump Tightness Test Date	05/05/2022	Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/05/2022	Line Tightness Test Date	02/28/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	05/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/Red Jacket FXIV;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Belgrade

Location: CIRCLE K STORE 2746506
402 Belgrade BLVD
Belgrade, MT 59714 Gallatin

System Facility ID:60-15351

Facility Code: 32437
Last Inspected On: 05/05/2021
Operating Permit Renewal Date: 08/01/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Rocky Mountain Oil LLC	6027288000
Operator Contact:	Veronica Rivera	

Owner/Operator:	Rocky Mountain Oil LLC
	Kenneth Sheehan, UST Class B Global Operator
	Veronica Rivera, UST Class A Operator

Tank Code	1	Tank Age	1	Tank Installed Date	01/23/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6016	Spill Test Date	02/02/2021	Piping Installed Date	01/23/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date	02/24/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/02/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	2	Tank Age	1	Tank Installed Date	01/23/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6017	Spill Test Date	02/02/2021	Piping Installed Date	01/23/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date	02/24/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/02/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	3	Tank Age	1	Tank Installed Date	01/23/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6018	Spill Test Date	02/02/2021	Piping Installed Date	01/23/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/23/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/02/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				
Tank Code	4	Tank Age	1	Tank Installed Date	01/23/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6019	Spill Test Date	02/02/2021	Piping Installed Date	01/23/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/23/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	02/23/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	02/02/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-550 EVO				

Facility Summary in Gallatin County in the City of Belgrade

Location: FLYING J INC BELGRADE
6505 Jackrabbit Ln
Belgrade, MT 59714-8990 Gallatin

System Facility ID:16-05753

Facility Code: 21368
Last Inspected On: 10/12/2020
Operating Permit Renewal Date: 12/17/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	A and H Investments LLC	5095341502
Operator Contact:	Randell Goff	4065391156

Owner/Operator: A and H Investments LLC

Randell Goff, UST Class A Operator
Randell Goff, UST Class B Global Operator

Tank Code	01	Tank Age	46	Tank Installed Date	04/26/1976	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3793	Spill Test Date		Piping Installed Date	08/31/2011	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	28000	ATG Test Date		Line Tightness Test Date	10/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	46	Tank Installed Date	04/26/1976	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3794	Spill Test Date	01/15/2021	Piping Installed Date	08/31/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/05/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/06/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	28000	ATG Test Date		Line Tightness Test Date	08/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	46	Tank Installed Date	04/26/1976	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3795	Spill Test Date	02/01/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	46	Tank Installed Date	04/01/1976	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3796	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/05/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/06/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	46	Tank Installed Date	04/26/1976	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3797	Spill Test Date		Piping Installed Date	08/31/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/05/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/06/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	28000	ATG Test Date		Line Tightness Test Date	07/28/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;ELLD 0.2	Energy Act	No

		Overfill Test Date			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	--------------------	--	--	----------	--	--	--	--	--

Facility Summary in Gallatin County in the City of Belgrade

Location: GALLATIN FIELD AIRPORT
633 Gallatin Field Rd
Belgrade, MT 59714 Gallatin

System Facility ID:60-15152

Facility Code: 30893
Last Inspected On: 07/01/2022
Operating Permit Renewal Date: 07/03/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Parkland USA Corporation	7018521194
-------------------------	--------------------------	------------

Operator Contact:	
-------------------	--

Owner/Operator:	Parkland USA Corporation
-----------------	--------------------------

Tank Code	01	Tank Age	12	Tank Installed Date	04/13/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5236	Spill Test Date	07/01/2022	Piping Installed Date	04/08/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/19/2022	Sump Tightness Test Date	12/26/2012	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/19/2022	Line Tightness Test Date	07/01/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	07/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/Red Jacket FXIV;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Belgrade

Location: QWEST COMMUNICATIONS
95 N Broadway
Belgrade, MT 59714-3702 Gallatin

System Facility ID:56-13996

Facility Code: 30657
Last Inspected On: 09/22/2020
Operating Permit Renewal Date: 03/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Qwest Corporation/Century Link

Operator Contact: Kevin Robison;Stephanie Miller;Thomas Pitts2063467532;5016808141;8015983020

Owner/Operator: Qwest Corporation/Century Link

- Kevin Robison, UST Class A Operator
- Kevin Robison, UST Class B Global Operator
- Stephanie Miller, UST Class A Operator
- Stephanie Miller, UST Class B Global Operator
- Thomas Pitts, UST Class A Operator
- Thomas Pitts, UST Class B Global Operator
- Thomas Pitts, UST Class B Operator

Tank Code	01	Tank Age	21	Tank Installed Date	11/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4266	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date	09/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Belgrade

Location: ROCKY MOUNTAIN SUPPLY INC BELGRADE350 Jackrabbit LnBelgrade, MT 59714-3035 GallatinFacility Code: 21757Last Inspected On: 02/15/2021Operating Permit Renewal Date: 02/26/2024System Facility ID:16-12101

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Supply Inc4063884009

Operator Contact: Jason Rorabaugh4063884008

Owner/Operator: Rocky Mountain Supply Inc

- Bill Balliet, UST Class B Operator
- Jason Rorabaugh, UST Class A Operator

Jason Rorabaugh, UST Class B Operator
Jeremy Huckleberry, UST Class B Operator

Tank Code	01	Tank Age	32	Tank Installed Date	09/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1189	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/24/2020	Tank/Piping CP Test Date	09/18/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	12/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/				
Tank Code	02	Tank Age	32	Tank Installed Date	09/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1190	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/24/2020	Tank/Piping CP Test Date	09/18/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	12/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/				
Tank Code	03	Tank Age	32	Tank Installed Date	09/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1191	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/24/2020	Tank/Piping CP Test Date	09/18/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	11/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/				

Tank Code	04	Tank Age	32	Tank Installed Date	09/20/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1192	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/24/2020	Tank/Piping CP Test Date	09/18/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	11/20/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/				
Tank Code	05	Tank Age	19	Tank Installed Date	10/24/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4867	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/24/2020	Tank/Piping CP Test Date	12/13/2014	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/				
Tank Code	06	Tank Age	3	Tank Installed Date	04/01/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5896	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/24/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date		Line Tightness Test Date	12/15/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root;/Veeder Root/TLS-450				

Tank Code	07	Tank Age	3	Tank Installed Date	04/01/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5897	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/24/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/14/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root;/Veeder Root/TLS-450				
Tank Code	08	Tank Age	3	Tank Installed Date	04/01/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5898	Spill Test Date		Piping Installed Date	04/01/2019	Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2;ELLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Belgrade

Location: TOWN PUMP INC BELGRADE
206 W Jefferson Ave
Belgrade, MT 59714-4406 Gallatin

System Facility ID:16-13625

Facility Code: 21840
Last Inspected On: 08/23/2022
Operating Permit Renewal Date: 10/27/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Belgrade 1 Town Pump LLC

4064976700

Operator Contact: Trent Biggers

Owner/Operator: Belgrade 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	27	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2454	Spill Test Date	04/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	04/21/2021	Line Tightness Test Date	06/30/2015	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/08/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	27	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2455	Spill Test Date	04/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	04/21/2021	Line Tightness Test Date	06/30/2015	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	27	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2456	Spill Test Date	04/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Safe Suction	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	04/21/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	27	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2458	Spill Test Date	05/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/21/2021	Line Tightness Test Date	06/30/2015	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	27	Tank Installed Date	05/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4371	Spill Test Date	04/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	04/21/2021	Line Tightness Test Date	06/30/2015	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Belgrade

Location: TOWN PUMP INC BELGRADE 2
691 Jackrabbit Ln
Belgrade, MT 59714-3034 Gallatin

System Facility ID:60-15008

Facility Code: 30798
Last Inspected On: 08/26/2022
Operating Permit Renewal Date: 09/16/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Belgrade 2 Town Pump LLC

4064976700

Operator Contact: Trent Biggers

Owner/Operator: Belgrade 2 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	17	Tank Installed Date	09/20/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5019	Spill Test Date	06/23/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	25000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	02	Tank Age	17	Tank Installed Date	09/20/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5020	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	03	Tank Age	17	Tank Installed Date	09/20/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve

Tag Number	5021	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	04	Tank Age	17	Tank Installed Date	09/20/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5022	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	05	Tank Age	17	Tank Installed Date	09/20/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5023	Spill Test Date	06/23/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/28/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	07/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				

Facility Summary in Gallatin County in the City of Belgrade

Location: TOWN PUMP INC BELGRADE 3
305 E Main St
Belgrade, MT 59714-3850 Gallatin

Facility Code: 21453
Last Inspected On: 01/05/2021
System Facility ID:16-07788
Operating Permit Renewal Date: 05/31/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Belgrade 3 Town Pump LLC	4064976700
Operator Contact:	Trent Biggers	

Owner/Operator: Belgrade 3 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	07	Tank Age	17	Tank Installed Date	08/29/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5016	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	09/11/2005	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	08	Tank Age	17	Tank Installed Date	08/29/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5017	Spill Test Date	06/23/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	09/11/2005	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				

Tank Code	09	Tank Age	17	Tank Installed Date	08/29/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5026	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	09/11/2005	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				

Facility Summary in Gallatin County in the City of Belgrade

Location:	TOWN PUMP INC BELGRADE 4 561 Business Hub Dr Belgrade, MT 59714 Gallatin	Facility Code:	30962
		Last Inspected On:	07/21/2022
	System Facility ID:60-15245	Operating Permit Renewal Date:	07/22/2025
Note: Inspection is due 90 days before the Operating Permit Renewal Date.			

Owner Operator Contact:	Belgrade 4 Town Pump LLC	4064976700
-------------------------	--------------------------	------------

Operator Contact:	Trent Biggers
-------------------	---------------

Owner/Operator:	Belgrade 4 Town Pump LLC
-----------------	--------------------------

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5484	Spill Test Date	08/10/2021	Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5485	Spill Test Date	08/10/2021	Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5486	Spill Test Date	08/10/2021	Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5487	Spill Test Date	10/05/2021	Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/24/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes

Capacity	30000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5488	Spill Test Date	08/10/2021	Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/24/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5489	Spill Test Date	08/10/2021	Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	07	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5490	Spill Test Date	08/10/2021	Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/14/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel, Dyed	PLLD Test Date	05/24/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/24/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	08	Tank Age	8	Tank Installed Date	04/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff
Tag Number	5491	Spill Test Date		Piping Installed Date	03/27/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Gallatin County in the City of Belgrade

Location: YELLOWSTONE JET CENTER LLC
456 Wings Way
Belgrade, MT 59714-8544 Gallatin

Facility Code: 21287
Last Inspected On: 06/22/2021
System Facility ID:16-04440
Operating Permit Renewal Date: 08/04/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Signature Flight Support 4076487265

Operator Contact: Al Sandvold;Michael Russell 4063883821

Owner/Operator: Signature Flight Support

Al Sandvold, UST Class A Operator
Michael Russell, UST Class A Operator
Robert Lemon, UST Class B Operator

Tank Code	01	Tank Age	45	Tank Installed Date	04/11/1977	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2036	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	10/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/22/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	02	Tank Age	45	Tank Installed Date	04/11/1977	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2037	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	10/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/22/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	03	Tank Age	45	Tank Installed Date	04/11/1977	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2038	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	10/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/22/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	04	Tank Age	47	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2039	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	10/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	06/22/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	05	Tank Age	47	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2040	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	10/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/22/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	06	Tank Age	47	Tank Installed Date	04/12/1975	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2041	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	10/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/22/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	07	Tank Age	47	Tank Installed Date	04/12/1975	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2042	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	10/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/22/2021			ATG Type	Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Big Sky

Location: BIG SKY CONOCO
91 Lone Mountain Trl
Big Sky, MT 59716 Gallatin

System Facility ID:16-03801

Facility Code: 21263
Last Inspected On: 07/18/2022
Operating Permit Renewal Date: 10/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nevermore Inc

Operator Contact: Renae Schumacher;Steve Schumacher **4065811357;4069954275**

Owner/Operator: Nevermore Inc

Renae Schumacher, UST Class A Operator
Steve Schumacher, UST Class A Operator
Steve Schumacher, UST Class B Operator

Tank Code	06	Tank Age	25	Tank Installed Date	05/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3155	Spill Test Date	06/29/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/29/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	06/29/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Veeder Root/TLS-350				
Tank Code	07	Tank Age	25	Tank Installed Date	05/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3156	Spill Test Date	06/29/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/29/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	06/29/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Veeder Root/TLS-350				
Tank Code	S8	Tank Age	25	Tank Installed Date	05/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3157	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-350				
Tank Code	09	Tank Age	21	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4488	Spill Test Date	06/29/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/05/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2500	ATG Test Date	06/29/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	06/29/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Veeder Root/TLS-350				
Tank Code	10	Tank Age	0	Tank Installed Date		Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6127	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Under Construction	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	11	Tank Age	0	Tank Installed Date		Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6128	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Under Construction	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Tank Code	12	Tank Age	0	Tank Installed Date		Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6129	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Under Construction	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	13	Tank Age	0	Tank Installed Date		Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6130	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Under Construction	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Gallatin County in the City of Big Sky

Location: KUNES MONTANA PROPERTY LLC
2300 N Fork Rd
Big Sky, MT 59716 Gallatin

Facility Code: 21844
Last Inspected On: 07/13/2022
System Facility ID:16-13672
Operating Permit Renewal Date: 12/06/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gregg Kunes2627493014

Operator Contact: Jay Reader

Owner/Operator: Gregg Kunes

Dennis Franks, UST Class B Global Operator
Jay Reader, UST Class A Operator
Jay Reader, UST Class B Global Operator

Tank Code	02	Tank Age	24	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
-----------	----	----------	----	---------------------	------------	---------------	-------------------------------	-----------------	------------------	----------------	--------------------------------

Tag Number	3726	Spill Test Date	05/23/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2022			ATG Type	Gilbarco-Veeder Root/TLS-300				
Tank Code	01	Tank Age	27	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3936	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/23/2022	Sump Tightness Test Date	05/23/2022	Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	05/23/2022	Line Tightness Test Date	12/02/2019	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/23/2022			ATG Type	Veeder Root/Red Jacket FXIV;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Big Sky

Location: SPANISH PEAKS LODGE
995 Settlement Trail
Big Sky, MT 59716 Gallatin

System Facility ID:60-15334

Facility Code: 32347
Last Inspected On: 03/30/2022
Operating Permit Renewal Date: 11/09/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	SP Hotel Owner, LLP	4069955140
Operator Contact:	John Douglas;Stephen Mickulas	

Owner/Operator: SP Hotel Owner, LLP

John Douglas, UST Class A Operator
John Douglas, UST Class B Global Operator
Stephen Mickulas, UST Class A Operator
Stephen Mickulas, UST Class B Global Operator

Tank Code	1	Tank Age	1	Tank Installed Date	08/19/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5915	Spill Test Date	09/12/2022	Piping Installed Date	08/19/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/13/2021	Catastrophic L.D Type 3.0	Auto Dialer;Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	03/30/2022	Line Tightness Test Date	09/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/30/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Other/Other				

Facility Summary in Gallatin County in the City of Big Sky

Location: WATERMARK HOME
341 Andesite Ridge Rd
Big Sky, MT 59716 Gallatin

System Facility ID:60-15032

Facility Code: 30815
Last Inspected On: 12/09/2019
Operating Permit Renewal Date: 01/11/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Watermark Services

4062091400

Operator Contact: Edd Gryder

Owner/Operator: Watermark Services

Edd Gryder, UST Class A Operator

Edd Gryder, UST Class B Operator

Tank Code	01	Tank Age	16	Tank Installed Date	10/24/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5133	Spill Test Date	09/18/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/09/2019	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	09/18/2021	Line Tightness Test Date	12/09/2019	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date	09/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Bozeman

Location: BLUE BASKET # 4
1035 Reeves Rd
Bozeman, MT 59718-7731 Gallatin

System Facility ID:16-13115

Facility Code: 21812
Last Inspected On: 03/23/2022
Operating Permit Renewal Date: 06/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Blue Basket Markets Billings

4062520166

Operator Contact: Brit Miller

4062520166

Owner/Operator: Blue Basket Markets Billings

Brit Miller, UST Class A Operator

Susie Breen, UST Class B Operator

Tank Code	01	Tank Age	29	Tank Installed Date	04/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
-----------	----	----------	----	---------------------	------------	---------------	------------------------------	-----------------	-------------------------------	----------------	------------------

Tag Number	456	Spill Test Date	11/04/2019	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/21/2021	Tank/Piping CP Test Date	03/23/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/21/2021	Line Tightness Test Date	11/08/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/21/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	29	Tank Installed Date	04/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	457	Spill Test Date	11/04/2019	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/21/2021	Tank/Piping CP Test Date	03/23/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/21/2021	Line Tightness Test Date	11/07/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/21/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	29	Tank Installed Date	04/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	458	Spill Test Date	02/25/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	09/21/2021	Tank/Piping CP Test Date	03/23/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/21/2021	Line Tightness Test Date	11/06/2018	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/21/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Gallatin County in the City of Bozeman

Location: BOZEMAN DEACONESS HOSPITAL
915 Highland Blvd
Bozeman, MT 59715-6902 Gallatin

System Facility ID:16-09771

Facility Code: 21534
Last Inspected On: 01/21/2021
Operating Permit Renewal Date: 04/05/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bozeman Deaconess Hospital

4064141091

Owner/Operator: Bozeman Deaconess Hospital

Jason Cocke, UST Class A Operator
Jason Cocke, UST Class B Global Operator
Jason Cocke, UST Class B Operator
Michael Dawson, UST Class B Operator
William Buhl, UST Class A Operator
William Buhl, UST Class B Operator

Tank Code	S3	Tank Age	18	Tank Installed Date	07/15/2004	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	4940	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/25/2019	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/				
Tank Code	04	Tank Age	2	Tank Installed Date	09/29/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5932	Spill Test Date	09/21/2020	Piping Installed Date	09/29/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/21/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	22000	ATG Test Date		Line Tightness Test Date	09/29/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/21/2020			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	05	Tank Age	2	Tank Installed Date	09/29/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5933	Spill Test Date	09/21/2020	Piping Installed Date	09/29/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/21/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	09/29/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/21/2020			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: BOZEMAN KARDLOCK 300 E Griffin Dr Bozeman, MT 59715 Gallatin	Facility Code: 21485 Last Inspected On: 12/02/2019 Operating Permit Renewal Date: 01/15/2023
System Facility ID:16-08191	Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation	7018521194
--	------------

Operator Contact: Calvin Wilson

Owner/Operator: Parkland USA Corporation
Calvin Wilson, UST Class A Operator
Calvin Wilson, UST Class B Global Operator

Tank Code	01	Tank Age	44	Tank Installed Date	05/02/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3864	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/02/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/11/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	02	Tank Age	44	Tank Installed Date	05/02/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3865	Spill Test Date		Piping Installed Date	12/22/2010	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/02/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/11/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	44	Tank Installed Date	05/02/1978	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3866	Spill Test Date	02/21/2020	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/02/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/16/2010	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	36	Tank Installed Date	01/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3867	Spill Test Date	02/21/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/02/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	01/11/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	36	Tank Installed Date	01/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3868	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/02/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: BRIDGER BOWL INC 15795 Bridger Canyon Rd Bozeman, MT 59715-8282 Gallatin	Facility Code: 21177 Last Inspected On: 07/28/2021 Operating Permit Renewal Date: 10/01/2021
System Facility ID:16-01793	Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bridger Bowl Inc	4065872111
Operator Contact: David Rosengen;Robert Allen	4065872111

Owner/Operator: Bridger Bowl Inc

David Rosengen, UST Class A Operator
David Rosengen, UST Class B Operator
Robert Allen, UST Class A Operator

Tank Code	S7	Tank Age	26	Tank Installed Date	11/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic

Product	Other	PLLD Test Date		Tank/Piping CP Test Date	05/28/2009	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	08	Tank Age	24	Tank Installed Date	10/30/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	492	Spill Test Date	06/24/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/24/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/17/2021	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/24/2021			ATG Type					
Tank Code	09	Tank Age	24	Tank Installed Date	10/30/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	493	Spill Test Date	06/24/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/24/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/17/2021	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/24/2021			ATG Type					

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEY'S CORNER #1
81855 Gallatin Rd
Bozeman, MT 59718-8110 Gallatin

Facility Code: 21409
Last Inspected On: 04/13/2022
System Facility ID:16-06922
Operating Permit Renewal Date: 07/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Parkland USA Corporation	7018521194
Operator Contact:	Jamison Paulsen	4065879715
Owner/Operator:	Parkland USA Corporation	
	Jamison Paulsen, UST Class A Operator	
	Jamison Paulsen, UST Class B Operator	

Tank Code	04	Tank Age	31	Tank Installed Date	04/10/1991	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2018	Spill Test Date	08/10/2021	Piping Installed Date	11/22/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date	04/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/10/2021	Line Tightness Test Date	02/26/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/10/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	05	Tank Age	31	Tank Installed Date	04/10/1991	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2019	Spill Test Date	08/10/2021	Piping Installed Date	11/22/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date	04/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/10/2021	Line Tightness Test Date	02/26/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/10/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	06	Tank Age	31	Tank Installed Date	04/10/1991	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2020	Spill Test Date	08/10/2021	Piping Installed Date	11/22/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date	04/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/10/2021	Line Tightness Test Date	02/23/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/10/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	07	Tank Age	26	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2021	Spill Test Date	08/10/2021	Piping Installed Date	11/22/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Diesel	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date	04/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/10/2021	Line Tightness Test Date	02/22/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/10/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	08	Tank Age	26	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2022	Spill Test Date	08/10/2021	Piping Installed Date	11/22/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date	04/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/10/2021	Line Tightness Test Date	02/22/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/10/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	09	Tank Age	26	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2023	Spill Test Date	08/10/2021	Piping Installed Date	11/22/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date	04/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/10/2021	Line Tightness Test Date	02/22/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/10/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	10	Tank Age	26	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2024	Spill Test Date	08/10/2021	Piping Installed Date	11/22/2017	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/10/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date	04/13/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/10/2021	Line Tightness Test Date	02/22/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	11	Tank Age	5	Tank Installed Date	09/17/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material		Overfill Types	Positive Shutoff
Tag Number	5769	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction		AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type		CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEY'S CORNER #2 1211 E Main St Bozeman, MT 59715 Gallatin	Facility Code: 21482 Last Inspected On: 08/15/2022 Operating Permit Renewal Date: 12/31/2025
System Facility ID:16-08188	Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation	7018521194
Operator Contact:	

Owner/Operator: Parkland USA Corporation
Robert Ward, UST Class B Operator
Tracy Miller, UST Class B Operator

Tank Code	06	Tank Age	24	Tank Installed Date	04/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2030	Spill Test Date	09/21/2021	Piping Installed Date	07/31/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	09/29/2022	Tank/Piping CP Test Date	08/15/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/29/2022	Line Tightness Test Date	06/10/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	01/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	07	Tank Age	24	Tank Installed Date	04/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2031	Spill Test Date	09/21/2021	Piping Installed Date	07/31/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/29/2022	Tank/Piping CP Test Date	08/15/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/29/2022	Line Tightness Test Date	06/10/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	24	Tank Installed Date	04/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4576	Spill Test Date	01/20/2022	Piping Installed Date	07/31/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/29/2022	Tank/Piping CP Test Date	08/15/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/29/2022	Line Tightness Test Date	06/16/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	24	Tank Installed Date	04/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4577	Spill Test Date	01/20/2022	Piping Installed Date	07/31/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/21/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/29/2022	Tank/Piping CP Test Date	08/15/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	4000	ATG Test Date	09/29/2022	Line Tightness Test Date	06/10/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	01/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEYS CORNER #3 1420 N 7th Ave Bozeman, MT 59715 Gallatin	Facility Code: 21484 Last Inspected On: 08/15/2022 Operating Permit Renewal Date: 12/31/2025
System Facility ID:16-08190	Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation	7018521194
--	------------

Operator Contact:

Owner/Operator: Parkland USA Corporation
--

Tank Code	06	Tank Age	24	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3687	Spill Test Date	08/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/29/2022	Tank/Piping CP Test Date	08/15/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	09/29/2022	Line Tightness Test Date	01/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	07	Tank Age	24	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3688	Spill Test Date	08/31/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	09/29/2022	Tank/Piping CP Test Date	08/15/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	14000	ATG Test Date	09/29/2022	Line Tightness Test Date	10/15/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	08	Tank Age	17	Tank Installed Date	12/28/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5054	Spill Test Date	08/15/2022	Piping Installed Date	11/16/2015	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/03/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/29/2022	Tank/Piping CP Test Date	10/07/2010	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/29/2022	Line Tightness Test Date	10/15/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/15/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: CASEYS CORNER 5
4135 Valley Commons Dr
Bozeman, MT 59718-6427 Gallatin

System Facility ID:16-13775

Facility Code: 21847
Last Inspected On: 10/24/2019
Operating Permit Renewal Date: 02/19/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation7018521194

Operator Contact: Calvin Wilson

Owner/Operator: Parkland USA Corporation

Calvin Wilson, UST Class A Operator

Calvin Wilson, UST Class B Global Operator
Damian Lewis, UST Class B Global Operator
David Lingenfelter, UST Class B Operator
Kelly Shutes, UST Class B Global Operator
Kelsey Grubb, UST Class B Operator
Lisa Anderson, UST Class B Operator

Tank Code	01	Tank Age	24	Tank Installed Date	03/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	3407	Spill Test Date		Piping Installed Date	06/08/2015	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/08/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	08/07/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				
Tank Code	02	Tank Age	24	Tank Installed Date	03/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3408	Spill Test Date	08/30/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	08/07/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/30/2022			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				
Tank Code	03	Tank Age	24	Tank Installed Date	03/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3409	Spill Test Date	12/27/2019	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	12000	ATG Test Date		Line Tightness Test Date	08/07/2013	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				

Facility Summary in Gallatin County in the City of Bozeman

Location: CIRCLE K STORE 2746305
1951 Durston Rd
Bozeman, MT 59718-2738 Gallatin

System Facility ID:56-13937

Facility Code: 30607
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Chuck Nyberg;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries;Veronica Rivera9528308028;9528308721;9528308722

Owner/Operator: Rocky Mountain Oil LLC

Brad Lee, UST Class B Global Operator
Chuck Nyberg, UST Class A Operator
Jeff Reed, UST Class B Global Operator
Patrick Patnaude, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Steve Ulery, UST Class B Operator
Todd White, UST Class B Global Operator
Valeria Jeffries, UST Class A Operator
Veronica Rivera, UST Class A Operator
Veronica Rivera, UST Class B Operator

Tank Code	01	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4047	Spill Test Date	06/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/30/2022	Tank/Piping CP Test Date	10/02/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	06/30/2022	Line Tightness Test Date	03/12/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	06/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4048	Spill Test Date	01/04/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/30/2022	Tank/Piping CP Test Date	10/02/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	06/30/2022	Line Tightness Test Date	03/12/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4051	Spill Test Date	06/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/30/2022	Tank/Piping CP Test Date	10/02/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/30/2022	Line Tightness Test Date	03/05/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4566	Spill Test Date	01/04/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/30/2022	Tank/Piping CP Test Date	10/02/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes

Capacity	8000	ATG Test Date	06/30/2022	Line Tightness Test Date	03/10/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4567	Spill Test Date	06/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/30/2022	Tank/Piping CP Test Date	10/02/2007	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	06/30/2022	Line Tightness Test Date	03/07/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/30/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location:	COLLEGE EXXON SERVICE STATION 723 S 8th Ave Bozeman, MT 59715-4414 Gallatin	Facility Code:	21108
		Last Inspected On:	06/03/2021
	System Facility ID:16-00472	Operating Permit Renewal Date:	08/20/2024
Note: Inspection is due 90 days before the Operating Permit Renewal Date.			

Owner Operator Contact: College Chevron of Bozeman Inc4065874453

Operator Contact: David Lapinski

Owner/Operator: College Chevron of Bozeman Inc

David Lapinski, UST Class A Operator
David Lapinski, UST Class B Operator

Tank Code	06	Tank Age	24	Tank Installed Date	04/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	694	Spill Test Date	06/03/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	05/10/2021	Sump Tightness Test Date	06/03/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/03/2021	Line Tightness Test Date	05/10/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	06/03/2021			ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000;Veeder Root/TLS-300				
Tank Code	07	Tank Age	24	Tank Installed Date	04/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	695	Spill Test Date	06/03/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/10/2021	Sump Tightness Test Date	06/03/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/03/2021	Line Tightness Test Date	05/10/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	06/03/2021			ATG Type	Vaporless Manufacturing/Vaporless 99LD-2000;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Bozeman

Location: COSTCO WHOLESALE GASOLINE BOZEMAN
2505 Catron St
Bozeman, MT 59718 Gallatin

Facility Code: 30846
Last Inspected On: 04/12/2022
Operating Permit Renewal Date: 08/22/2025

System Facility ID:60-15075

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Costco Wholesale

4252516222

Operator Contact: Charlie Brown;Devin Stewart;Herbert Burnell;Pamela Williams

4065798985

Owner/Operator: Costco Wholesale

Charlie Brown, UST Class A Operator
Charlie Brown, UST Class B Operator
Devin Stewart, UST Class A Operator

Herbert Burnell, UST Class A Operator
Herbert Burnell, UST Class B Operator
Pamela Williams, UST Class A Operator

Tank Code	01	Tank Age	15	Tank Installed Date	10/24/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5130	Spill Test Date	02/03/2020	Piping Installed Date	08/23/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/13/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/15/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date	09/15/2021	Line Tightness Test Date	09/15/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	15	Tank Installed Date	10/24/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5131	Spill Test Date	02/03/2020	Piping Installed Date	08/23/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/13/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/15/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	30000	ATG Test Date	09/15/2021	Line Tightness Test Date	09/15/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	15	Tank Installed Date	10/24/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5132	Spill Test Date	02/03/2020	Piping Installed Date	08/23/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/13/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/15/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	30000	ATG Test Date	09/15/2021	Line Tightness Test Date	09/15/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	11	Tank Installed Date	03/25/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5282	Spill Test Date	02/03/2020	Piping Installed Date	10/27/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/15/2021	Sump Tightness Test Date	01/13/2020	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1500	ATG Test Date	09/15/2021	Line Tightness Test Date	09/15/2021	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Vaporless Manufacturing/Vaporless LD-2000				

Facility Summary in Gallatin County in the City of Bozeman

Location: EXXONMOBIL BOZEMAN PRODUCTS TERMINAL
220 W Griffin Dr
Bozeman, MT 59715-2254 Gallatin

System Facility ID:16-08730

Facility Code: 21508
Last Inspected On: 09/24/2021
Operating Permit Renewal Date: 09/28/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Exxon Mobil Corporation Bozeman	8326257781
Operator Contact:	Bry Joaillier Allen;Christopher Martin;Clinton Robbins;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein	4062236901;4065866927;4066575404;4357647049;8326247774;8326247876

Owner/Operator:	Exxon Mobil Corporation Bozeman
	Bry Joaillier Allen, UST Class A Operator
	Bry Joaillier Allen, UST Class B Global Operator
	Christopher Martin, UST Class A Operator
	Christopher Martin, UST Class B Operator
	Clinton Robbins, UST Class A Operator
	Clinton Robbins, UST Class B Global Operator
	James Vokral, UST Class A Operator

James Vokral, UST Class B Global Operator
Janie Lee, UST Class A Operator
Janie Lee, UST Class B Global Operator
M Martin, UST Class A Operator
M Martin, UST Class B Global Operator
Michael Bailey, UST Class A Operator
Michael Bailey, UST Class B Global Operator
Michael James, UST Class A Operator
Michael James, UST Class B Global Operator
Robert Ochsenbein, UST Class A Operator
Robert Ochsenbein, UST Class B Global Operator

Tank Code	S19	Tank Age	42	Tank Installed Date	01/01/1980	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	Impressed Current
Product	Oil/Water Separator	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S1	Tank Age	68	Tank Installed Date	06/01/1954	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2805	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	630000	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	68	Tank Installed Date	06/01/1954	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2809	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	420000	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	68	Tank Installed Date	06/01/1954	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2811	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	630000	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	68	Tank Installed Date	06/01/1954	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2813	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	420000	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S11	Tank Age	68	Tank Installed Date	06/01/1954	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2815	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Other	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	420000	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S12	Tank Age	68	Tank Installed Date	06/01/1954	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2816	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/24/2011	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	420000	ATG Test Date		Line Tightness Test Date	10/25/2012	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	S22	Tank Age	68	Tank Installed Date	01/01/1954	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2817	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	110	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S24	Tank Age	68	Tank Installed Date	01/01/1954	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2819	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	110	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S36	Tank Age	31	Tank Installed Date	04/01/1991	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2824	Spill Test Date		Piping Installed Date	12/29/2016	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/11/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S37	Tank Age	35	Tank Installed Date	09/01/1987	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2825	Spill Test Date		Piping Installed Date	12/29/2016	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/11/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S40	Tank Age	28	Tank Installed Date	05/01/1994	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number	2828	Spill Test Date		Piping Installed Date	12/29/2016	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/11/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	21	Tank Age	34	Tank Installed Date	06/01/1988	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	3702	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S3	Tank Age	68	Tank Installed Date	06/01/1954	Tank Material	Bare Steel	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	4851	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/22/2021	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1260000	ATG Test Date		Line Tightness Test Date	09/30/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Gallatin County in the City of Bozeman

Location: GRANTREE CONOCO
1417 N 7th Ave
Bozeman, MT 59715-2513 Gallatin

System Facility ID:16-01254

Facility Code: 21148
Last Inspected On: 08/15/2022
Operating Permit Renewal Date: 12/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Grantree Conoco **4065875261**

Operator Contact: Miki Marshall **4065870651**

Owner/Operator: Grantree Conoco
Miki Marshall, UST Class A Operator
Miki Marshall, UST Class B Operator

Tank Code	05	Tank Age	27	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3299	Spill Test Date	08/15/2022	Piping Installed Date	04/14/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/05/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/24/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	04/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	27	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3300	Spill Test Date	08/15/2022	Piping Installed Date	04/14/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/05/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/24/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Tank Code	07	Tank Age	27	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3301	Spill Test Date	08/15/2022	Piping Installed Date	04/14/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/05/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/24/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	04/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	08	Tank Age	27	Tank Installed Date	09/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3302	Spill Test Date	08/15/2022	Piping Installed Date	04/14/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/05/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	10/24/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	06/04/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: KAGY KORNER INC
1809 S Tracy Ave
Bozeman, MT 59715-5736 Gallatin

System Facility ID:16-09672

Facility Code: 21532
Last Inspected On: 03/09/2020
Operating Permit Renewal Date: 07/15/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Kagy Korner Store Inc4065861079

Operator Contact: Amber Wilkinson;Rhett Tschache4065703470

Owner/Operator: Kagy Korner Store Inc

Amber Wilkinson, UST Class A Operator
Amber Wilkinson, UST Class B Operator
Rhett Tschache, UST Class A Operator
Rhett Tschache, UST Class B Operator

Tank Code	01	Tank Age	35	Tank Installed Date	11/15/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1462	Spill Test Date		Piping Installed Date	06/29/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/22/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/13/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	35	Tank Installed Date	11/15/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1463	Spill Test Date		Piping Installed Date	06/29/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/22/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/13/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	35	Tank Installed Date	11/15/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1464	Spill Test Date		Piping Installed Date	06/29/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/22/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date		Line Tightness Test Date	03/13/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: LOAF 'N JUG #728
717 W College St
Bozeman, MT 59715 Gallatin

System Facility ID:16-05778

Facility Code: 21369
Last Inspected On: 02/03/2022
Operating Permit Renewal Date: 03/02/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Operator Contact: John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

David Cordova, UST Class B Global Operator
David Cordova, UST Class B Operator
Hiede Richardson, UST Class B Global Operator
Jennifer Coleman, UST Class B Global Operator
John Sumowski, UST Class A Operator
Randal Liebnow, UST Class A Operator
Randal Liebnow, UST Class B Global Operator
Scott Huether, UST Class B Global Operator
Stevie Ulstad, UST Class B Operator
Theodore Bezel, UST Class A Operator
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Operator
Timothy Osterman, UST Class B Operator
Toni Mullen, UST Class B Global Operator

Tank Code	01	Tank Age	41	Tank Installed Date	04/25/1981	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3641	Spill Test Date	03/02/2021	Piping Installed Date	12/26/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLLD Test Date	02/03/2022	Tank/Piping CP Test Date	03/20/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/03/2022	Line Tightness Test Date	12/18/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	04/25/1981	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3642	Spill Test Date	03/02/2021	Piping Installed Date	12/26/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	02/03/2022	Tank/Piping CP Test Date	03/20/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/03/2022	Line Tightness Test Date	12/18/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	41	Tank Installed Date	04/25/1981	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3643	Spill Test Date	03/02/2021	Piping Installed Date	12/26/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	02/03/2022	Tank/Piping CP Test Date	03/20/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/03/2022	Line Tightness Test Date	12/18/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: LOAF 'N JUG #729 1910 W Main St Bozeman, MT 59718-3906 Gallatin	System Facility ID:16-03913	Facility Code: 21271 Last Inspected On: 02/02/2022 Operating Permit Renewal Date: 06/14/2025
Note: Inspection is due 90 days before the Operating Permit Renewal Date.		

Owner Operator Contact: Mini Mart Inc dba Loaf 'N Jug Pueblo5139641568

Operator Contact: John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc 5139641568
dba Loaf 'N Jug Pueblo

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

Hiede Richardson, UST Class B Global Operator
Jennifer Coleman, UST Class B Global Operator
Jody Hale, UST Class B Operator
John Sumowski, UST Class A Operator
Randal Liebnow, UST Class A Operator
Randal Liebnow, UST Class B Global Operator
Scott Huether, UST Class B Global Operator
Scott Huether, UST Class B Operator
Stevie Ulstad, UST Class B Operator
Theodore Bezel, UST Class A Operator
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Operator
Timothy Osterman, UST Class B Global Operator
Timothy Osterman, UST Class B Operator
Toni Mullen, UST Class B Global Operator

Tank Code	13	Tank Age	37	Tank Installed Date	11/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1639	Spill Test Date	03/02/2021	Piping Installed Date	05/03/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date	02/02/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/02/2022	Line Tightness Test Date	10/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	37	Tank Installed Date	11/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1640	Spill Test Date	03/28/2022	Piping Installed Date	05/03/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date	02/02/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date	02/02/2022	Line Tightness Test Date	10/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	31	Tank Age	37	Tank Installed Date	11/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1641	Spill Test Date	03/02/2021	Piping Installed Date	05/03/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date	02/02/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/02/2022	Line Tightness Test Date	10/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	32	Tank Age	37	Tank Installed Date	11/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1642	Spill Test Date	03/02/2021	Piping Installed Date	05/03/2018	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date	02/02/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/02/2022	Line Tightness Test Date	10/01/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: PHILLIPS 66 BOZEMAN TERMINAL
318 W Griffin Dr
Bozeman, MT 59715 Gallatin

System Facility ID:16-01844

Facility Code: 21181
Last Inspected On: 07/14/2020
Operating Permit Renewal Date: 10/31/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Phillips 66 Pipeline LLC 4062555714

Operator Contact: Chase Keith;Joshua Brown 4062239892;4068556044

Owner/Operator: Phillips 66 Pipeline LLC

Chase Keith, UST Class A Operator
Chase Keith, UST Class B Global Operator
Joshua Brown, UST Class A Operator
Joshua Brown, UST Class B Operator

Tank Code	23	Tank Age	22	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4698	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/24/2014	Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	05/01/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1500	ATG Test Date		Line Tightness Test Date	07/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Other/Other				
Tank Code	S6	Tank Age	67	Tank Installed Date	01/01/1955	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	715	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/01/2020	Primary Tank Leak Detection		Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	07/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S10	Tank Age	67	Tank Installed Date	01/01/1955	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	716	Spill Test Date		Piping Installed Date	07/02/2013	Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/01/2020	Primary Tank Leak Detection		Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	07/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	67	Tank Installed Date	01/01/1955	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	717	Spill Test Date		Piping Installed Date	07/02/2013	Tank Construction		Piping Construction	None	AST	Yes

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/01/2020	Primary Tank Leak Detection		Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	07/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S12	Tank Age	67	Tank Installed Date	01/01/1955	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	720	Spill Test Date		Piping Installed Date	07/02/2013	Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/01/2020	Primary Tank Leak Detection		Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	840000	ATG Test Date		Line Tightness Test Date	07/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S14	Tank Age	56	Tank Installed Date	01/01/1966	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	722	Spill Test Date		Piping Installed Date	04/10/2015	Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	05/01/2020	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1680000	ATG Test Date		Line Tightness Test Date	05/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Gallatin County in the City of Bozeman

Location: RESSLER MOTOR COMPANY
8474 Huffine Ln
Bozeman, MT 59718-9421 Gallatin

Facility Code: 30861
Last Inspected On: 05/05/2021
System Facility ID:60-15102
Operating Permit Renewal Date: 08/18/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Ressler Motors Company	4065875501
Operator Contact:	Chad Karch;Tracy Mullins	5092172694
Owner/Operator:	Ressler Motors Company	

Chad Karch, UST Class A Operator
Chad Karch, UST Class B Operator
Tracy Mullins, UST Class A Operator
Tracy Mullins, UST Class B Global Operator

Tank Code	S1	Tank Age	14	Tank Installed Date	07/08/2008	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5178	Spill Test Date		Piping Installed Date	03/10/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1100	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	S2	Tank Age	14	Tank Installed Date	07/08/2008	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5179	Spill Test Date		Piping Installed Date	03/10/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/07/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1100	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Gallatin County in the City of Bozeman

Location: SAFEWAY FUEL 2999
1801 W Main St
Bozeman, MT 59715-4015 Gallatin

System Facility ID:16-05474

Facility Code: 21348
Last Inspected On: 09/14/2022
Operating Permit Renewal Date: 12/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Albertsons Inc Boise	2084217561
Operator Contact:	Jesse Wees;Steven Hernandez	2084127561
Owner/Operator:	Albertsons Inc Boise	

Jesse Wees, UST Class A Operator

Kenneth Matheys, UST Class B Global Operator
Steven Hernandez, UST Class A Operator
Steven Hernandez, UST Class B Global Operator

Tank Code	05	Tank Age	3	Tank Installed Date	06/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5870	Spill Test Date	06/09/2021	Piping Installed Date	06/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	09/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	06	Tank Age	3	Tank Installed Date	06/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5871	Spill Test Date	06/09/2021	Piping Installed Date	06/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/09/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	07	Tank Age	3	Tank Installed Date	06/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5872	Spill Test Date	06/09/2021	Piping Installed Date	06/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	15000	ATG Test Date	09/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	08	Tank Age	3	Tank Installed Date	06/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5873	Spill Test Date	06/09/2021	Piping Installed Date	06/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/13/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/14/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: SIME CONSTRUCTION 190 Ramshorn Dr Bozeman, MT 59718 Gallatin	System Facility ID:56-13960	Facility Code: 30627 Last Inspected On: 03/22/2022 Operating Permit Renewal Date: 06/29/2025
Note: Inspection is due 90 days before the Operating Permit Renewal Date.		

Owner Operator Contact: Sime Construction	4065829841
---	------------

Operator Contact: Shawn Sime

Owner/Operator: Sime Construction

Matthew Wilmeth, UST Class B Global Operator
Shawn Sime, UST Class A Operator

Tank Code	01	Tank Age	22	Tank Installed Date	01/01/2000	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4487	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/22/2022	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	03/22/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Pneumercator/Other				

Facility Summary in Gallatin County in the City of Bozeman

Location:	SMITHS #170 FUEL CENTER 1735 W Oak St Bozeman, MT 59715 Gallatin	Facility Code:	30951
		Last Inspected On:	05/21/2020
		Operating Permit Renewal Date:	06/16/2023
		System Facility ID:	60-15234
		Note: Inspection is due 90 days before the Operating Permit Renewal Date.	

Owner Operator Contact:	Smiths Food and Drug	8019741400
Operator Contact:	Braxton Hill;David Harris;Gary Dotseth;James Dye;Ronnie Houtekamer;Todd Dotseth	4064527649;4067882338;8015600471;8019741206;8019772012

Owner/Operator: Smiths Food and Drug

- Braxton Hill, UST Class A Operator
- Braxton Hill, UST Class B Operator
- David Harris, UST Class A Operator
- David Harris, UST Class B Global Operator
- Gary Dotseth, UST Class A Operator
- Gary Dotseth, UST Class B Global Operator
- James Dye, UST Class A Operator
- Ronnie Houtekamer, UST Class A Operator
- Ronnie Houtekamer, UST Class B Global Operator
- Todd Dotseth, UST Class A Operator
- Todd Dotseth, UST Class B Operator

Tank Code	01	Tank Age	9	Tank Installed Date	11/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5443	Spill Test Date		Piping Installed Date	11/04/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/10/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	9	Tank Installed Date	11/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5444	Spill Test Date		Piping Installed Date	11/04/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/10/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	9	Tank Installed Date	11/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5445	Spill Test Date		Piping Installed Date	11/04/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/10/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/10/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: THRIFTWAY SUPER STOP 10
919 W College St
Bozeman, MT 59715-5062 Gallatin

System Facility ID:16-03432

Facility Code: 21243
Last Inspected On: 01/31/2022
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc4064942305

Operator Contact: Bryan Kelsey;Louis Sutey4064915808

Owner/Operator: Sutey Oil Co Inc

Bryan Kelsey, UST Class A Operator
Bryan Kelsey, UST Class B Operator
Dan Franti, UST Class B Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator

Tank Code	02	Tank Age	39	Tank Installed Date	07/01/1983	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4434	Spill Test Date	01/20/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/01/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	01	Tank Age	39	Tank Installed Date	07/01/1983	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	812	Spill Test Date	06/14/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/01/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	39	Tank Installed Date	07/01/1983	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	814	Spill Test Date	01/20/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/01/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Bozeman

Location: THRIFTWAY SUPER STOP 11
621 W Main St
Bozeman, MT 59715-3468 Gallatin

Facility Code: 21262
Last Inspected On: 01/31/2022
Operating Permit Renewal Date: 06/12/2025
System Facility ID:16-03800

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Sutey Oil Co Inc	4064942305
Operator Contact:	Bryan Kelsey;Louis Sutey	4064915808

Owner/Operator: Sutey Oil Co Inc

Bryan Kelsey, UST Class A Operator
Bryan Kelsey, UST Class B Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator

Tank Code	06	Tank Age	32	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	815	Spill Test Date	01/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/31/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/09/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/31/2022	Line Tightness Test Date	01/31/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/31/2022			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	07	Tank Age	32	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	816	Spill Test Date	01/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	01/31/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/09/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/31/2022	Line Tightness Test Date	01/31/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/31/2022			ATG Type	Gilbarco-Veeder Root/EMC Basic				
Tank Code	08	Tank Age	32	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	817	Spill Test Date	06/15/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	01/31/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/09/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	01/31/2022	Line Tightness Test Date	01/31/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/31/2022			ATG Type	Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Gallatin County in the City of Bozeman

Location: THRIFTWAY SUPER STOP 8
8192 Huffine Ln
Bozeman, MT 59718-9420 Gallatin

System Facility ID:16-05064

Facility Code: 21319
Last Inspected On: 02/02/2022
Operating Permit Renewal Date: 05/06/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Sutey Oil Co Inc	4064942305
Operator Contact:	Bryan Kelsey;Louis Sutey	4064915808

Owner/Operator: Sutey Oil Co Inc

Bryan Kelsey, UST Class A Operator
Bryan Kelsey, UST Class B Operator
Dave Stine, UST Class B Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator
Matthew Nichols, UST Class B Global Operator

Tank Code	05	Tank Age	24	Tank Installed Date	08/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
-----------	----	----------	----	---------------------	------------	---------------	-------------------------------	-----------------	------------------	----------------	---------------

Tag Number	2053	Spill Test Date	05/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	02/02/2022	Line Tightness Test Date	09/05/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	24	Tank Installed Date	08/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2054	Spill Test Date	05/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	02/02/2022	Line Tightness Test Date	09/05/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	07	Tank Age	24	Tank Installed Date	08/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2055	Spill Test Date	05/27/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/02/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	02/02/2022	Line Tightness Test Date	09/05/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP BOZEMAN 6
2525 N 19th Ave
Bozeman, MT 59715 Gallatin

System Facility ID:60-15339

Facility Code: 32386
Last Inspected On: 08/23/2022
Operating Permit Renewal Date: 09/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings Holdings LLC

Operator Contact: Trent Biggers

Owner/Operator: Billings Holdings LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	2	Tank Installed Date	11/23/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5938	Spill Test Date	08/11/2021	Piping Installed Date	11/23/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	06/29/2022	Line Tightness Test Date	12/12/2020	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-5000 EVO				
Tank Code	02	Tank Age	2	Tank Installed Date	11/23/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5939	Spill Test Date	08/11/2021	Piping Installed Date	11/23/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes

Capacity	15000	ATG Test Date	06/29/2022	Line Tightness Test Date	12/12/2020	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-5000 EVO				
Tank Code	03	Tank Age	2	Tank Installed Date	11/23/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5940	Spill Test Date	08/11/2021	Piping Installed Date	11/23/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/29/2022	Line Tightness Test Date	12/12/2020	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-5000 EVO				
Tank Code	04	Tank Age	2	Tank Installed Date	11/23/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5941	Spill Test Date	08/11/2021	Piping Installed Date	11/23/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	06/29/2022	Line Tightness Test Date	12/12/2020	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-5000 EVO				
Tank Code	05	Tank Age	2	Tank Installed Date	11/23/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5942	Spill Test Date	08/11/2021	Piping Installed Date	11/23/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	06/29/2022	Line Tightness Test Date	12/12/2020	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-5000 EVO				
Tank Code	06	Tank Age	2	Tank Installed Date	11/23/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5943	Spill Test Date	08/11/2021	Piping Installed Date	11/23/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/16/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	06/29/2022	Line Tightness Test Date	12/12/2020	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/11/2021			ATG Type	Franklin Fueling Systems/TS-LS500 Series;Incon/TS-5000 EVO				

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP BOZEMAN 7
1871 Baxter Ln
Bozeman, MT 59715 Gallatin

System Facility ID:60-15205

Facility Code: 30925
Last Inspected On: 08/17/2022
Operating Permit Renewal Date: 08/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bozeman 7 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Bozeman 7 Town Pump LLC

Trent Biggers, UST Class A Operator

Tank Code	02	Tank Age	10	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5348	Spill Test Date	08/18/2021	Piping Installed Date	12/01/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	05/04/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	10	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5349	Spill Test Date	07/12/2021	Piping Installed Date	12/01/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/04/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	10	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5350	Spill Test Date	05/04/2021	Piping Installed Date	12/01/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/04/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	10	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5351	Spill Test Date	05/04/2021	Piping Installed Date	12/01/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/04/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	10	Tank Installed Date	12/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5352	Spill Test Date	05/04/2021	Piping Installed Date	12/01/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/04/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/04/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of Bozeman

Location:	TOWN PUMP INC BOZEMAN #10 77 East Valley Center Road Bozeman, MT 59715 Gallatin	Facility Code:	32426
		Last Inspected On:	07/21/2022
	System Facility ID:60-15346	Operating Permit Renewal Date:	07/25/2025
Note: Inspection is due 90 days before the Operating Permit Renewal Date.			

Owner Operator Contact: Town Pump Inc Northwest Missoula

Operator Contact: Trent Biggers

Owner/Operator: Town Pump Inc Northwest Missoula

Trent Biggers, UST Class A Operator											
Trent Biggers, UST Class B Global Operator											
Tank Code	01	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5985	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	02	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5986	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	03	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5987	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	04	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	5988	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	05	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5989	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	06	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5990	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				

Tank Code	07	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5991	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	08	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5992	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	09	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5993	Spill Test Date	08/12/2021	Piping Installed Date	12/14/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	05/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD				
Tank Code	10	Tank Age	2	Tank Installed Date	12/14/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5994	Spill Test Date	09/01/2020	Piping Installed Date	12/14/2020	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/01/2020	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	7000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	12/11/2020			ATG Type					

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 1
803 E Main St
Bozeman, MT 59715-3842 Gallatin

Facility Code: 21505
Last Inspected On: 10/19/2022
System Facility ID:16-08674
Operating Permit Renewal Date: 08/25/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bozeman 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Bozeman 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	09	Tank Age	7	Tank Installed Date	04/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5520	Spill Test Date	03/29/2021	Piping Installed Date	10/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/29/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	20000	ATG Test Date	03/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	7	Tank Installed Date	04/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5521	Spill Test Date	03/29/2021	Piping Installed Date	10/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/29/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	7	Tank Installed Date	04/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5522	Spill Test Date	03/29/2021	Piping Installed Date	10/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/29/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	7	Tank Installed Date	04/01/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5523	Spill Test Date	03/29/2021	Piping Installed Date	10/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/29/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	03/29/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

		Overfill Test Date	05/03/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				
Tank Code	02	Tank Age	38	Tank Installed Date	04/11/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2442	Spill Test Date	05/31/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/12/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/08/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				
Tank Code	03	Tank Age	38	Tank Installed Date	04/11/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2443	Spill Test Date	07/08/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/12/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/03/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				
Tank Code	04	Tank Age	33	Tank Installed Date	04/01/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2444	Spill Test Date	07/08/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/12/2022	Tank/Piping CP Test Date	02/01/2018	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/12/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/03/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				
--	--	--------------------	------------	--	--	----------	---	--	--	--	--

Facility Summary in Gallatin County in the City of Bozeman

Location: TOWN PUMP INC BOZEMAN 5
29001 Norris Rd
Bozeman, MT 59718-8161 Gallatin

System Facility ID:60-15119

Facility Code: 30866
Last Inspected On: 07/10/2022
Operating Permit Renewal Date: 07/14/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Bozeman 5 Town Pump LLC	4064976700
-------------------------	-------------------------	------------

Operator Contact:	Trent Biggers
-------------------	---------------

Owner/Operator:	Bozeman 5 Town Pump LLC
-----------------	-------------------------

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	14	Tank Installed Date	12/08/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5191	Spill Test Date	04/07/2021	Piping Installed Date	06/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/23/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	14000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	04/06/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	14	Tank Installed Date	12/08/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5192	Spill Test Date	04/07/2021	Piping Installed Date	06/25/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/23/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	6000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/06/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	14	Tank Installed Date	12/08/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5193	Spill Test Date	04/07/2021	Piping Installed Date	06/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/23/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	14000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	04/06/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	14	Tank Installed Date	12/08/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5194	Spill Test Date	04/07/2021	Piping Installed Date	06/25/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/23/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/06/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	14	Tank Installed Date	12/08/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5195	Spill Test Date	04/07/2021	Piping Installed Date	06/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/23/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	04/06/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	06	Tank Age	5	Tank Installed Date	06/06/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5736	Spill Test Date	04/07/2021	Piping Installed Date	06/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/15/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/23/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	05/23/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	04/06/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of Bozeman

Location:	TOWN PUMP INC BOZEMAN 8 5200 S Cottonwood Rd Bozeman, MT 59718 Gallatin	Facility Code:	30961
		Last Inspected On:	11/04/2020
	System Facility ID:60-15244	Operating Permit Renewal Date:	03/05/2024
Note: Inspection is due 90 days before the Operating Permit Renewal Date.			

Owner Operator Contact:	Bozeman 8 Town Pump LLC	4064976700
-------------------------	-------------------------	------------

Operator Contact:	Trent Biggers
-------------------	---------------

Owner/Operator:	Bozeman 8 Town Pump LLC
-----------------	-------------------------

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	8	Tank Installed Date	08/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5479	Spill Test Date		Piping Installed Date	06/28/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	02	Tank Age	8	Tank Installed Date	08/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5480	Spill Test Date		Piping Installed Date	06/28/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	8	Tank Installed Date	08/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5481	Spill Test Date		Piping Installed Date	06/28/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	8	Tank Installed Date	08/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5482	Spill Test Date		Piping Installed Date	06/28/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	8	Tank Installed Date	08/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5483	Spill Test Date		Piping Installed Date	06/28/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/15/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of Bozeman

Location: WILLIAMS PUMP AND PAK INC
2020 N 7th Ave
Bozeman, MT 59715-2516 Gallatin

System Facility ID:16-00758

Facility Code: 21119
Last Inspected On: 09/17/2020
Operating Permit Renewal Date: 11/06/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Williams Pump and Pak Inc	4065870485
-------------------------	---------------------------	------------

Operator Contact:	Alan Williams
-------------------	---------------

Owner/Operator: Williams Pump and Pak Inc

Alan Williams, UST Class A Operator
Alan Williams, UST Class B Operator

Tank Code	04	Tank Age	25	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2275	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/17/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-350				
Tank Code	05	Tank Age	25	Tank Installed Date	06/01/1997	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2276	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/17/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-350				

Facility Summary in Gallatin County in the City of Bozeman

Location:	ZEKES LITTLE STORE INC 621 Bridger Dr Bozeman, MT 59715-2205 Gallatin	Facility Code: 21568 Last Inspected On: 04/09/2020 Operating Permit Renewal Date: 07/31/2023
	System Facility ID:16-10193	Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Zeke's Little Store, Inc	4065390576
Operator Contact:	David Huntley;Panda Harston;Stacy Huntley;William Harston	4065798371;4065876280

Owner/Operator: Zeke's Little Store, Inc

- David Huntley, UST Class A Operator
- David Huntley, UST Class B Operator
- Panda Harston, UST Class A Operator
- Panda Harston, UST Class B Operator
- Stacy Huntley, UST Class A Operator
- Stacy Huntley, UST Class B Operator
- William P Harston, UST Class A Operator
- William P Harston, UST Class B Operator

Tank Code	01	Tank Age	32	Tank Installed Date	01/05/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3067	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Tank Code	02	Tank Age	32	Tank Installed Date	01/05/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3068	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	03	Tank Age	32	Tank Installed Date	01/05/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4542	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Bozeman

Location:	ZIP TRIP 46 1210 E Main St Bozeman, MT 59715 Gallatin	System Facility ID:	16-06596	Facility Code:	21399
				Last Inspected On:	01/12/2022
				Operating Permit Renewal Date:	05/26/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	CHS Inc Spokane Valley	5095357701
-------------------------	------------------------	------------

Operator Contact:	Ian Johnstone;Jim Alford;Nicholas Merritt;Sean Hurley	4066330023;5095357701;5095367418
-------------------	---	----------------------------------

Owner/Operator:	CHS Inc Spokane Valley
-----------------	------------------------

- Darcy Ziegler, UST Class B Operator
- Ian Johnstone, UST Class A Operator
- Ian Johnstone, UST Class B Global Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator

Nicholas Merritt, UST Class A Operator
Nicholas Merritt, UST Class B Global Operator
Nicholas Merritt, UST Class B Operator
Sean Hurley, UST Class A Operator

Tank Code	01	Tank Age	37	Tank Installed Date	04/03/1985	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2105	Spill Test Date	08/25/2021	Piping Installed Date	06/18/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/18/2021	Tank/Piping CP Test Date	07/11/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/18/2021	Line Tightness Test Date	05/18/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	37	Tank Installed Date	04/03/1985	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2106	Spill Test Date	08/25/2021	Piping Installed Date	06/18/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	05/18/2021	Tank/Piping CP Test Date	07/11/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/18/2021	Line Tightness Test Date	05/18/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	37	Tank Installed Date	04/03/1985	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2107	Spill Test Date	08/25/2021	Piping Installed Date	06/18/2019	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	05/18/2021	Tank/Piping CP Test Date	07/11/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	8000	ATG Test Date	05/18/2021	Line Tightness Test Date	05/18/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/25/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Gallatin Gateway

Location: CASEY'S CORNER 6
47650 Gallatin Rd
Gallatin Gateway, MT 59730 Gallatin

System Facility ID:16-06923

Facility Code: 21410
Last Inspected On: 05/28/2020
Operating Permit Renewal Date: 09/10/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation7018521194

Operator Contact: Calvin Wilson;Damian Lewis

Owner/Operator: Parkland USA Corporation

Amber Wiatt, UST Class B Operator
Barbara Pozega, UST Class B Operator
Calvin Wilson, UST Class A Operator
Calvin Wilson, UST Class B Global Operator
Cheryl Caton, UST Class B Operator
Damian Lewis, UST Class A Operator
Damian Lewis, UST Class B Operator
Kelly Shutes, UST Class B Global Operator

Tank Code	01	Tank Age	37	Tank Installed Date	09/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4556	Spill Test Date	05/28/2020	Piping Installed Date	12/20/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	05/28/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Veeder Root/TLS-300				
Tank Code	02	Tank Age	37	Tank Installed Date	09/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4557	Spill Test Date	05/28/2020	Piping Installed Date	12/20/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/28/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Veeder Root/TLS-300				
Tank Code	03	Tank Age	37	Tank Installed Date	09/01/1985	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4558	Spill Test Date	05/28/2020	Piping Installed Date	12/20/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/28/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Gallatin Gateway

Location: CASEYS CORNER 9
76250 Gallatin Rd
Gallatin Gateway, MT 59730 Gallatin

System Facility ID:16-09998

Facility Code: 21546
Last Inspected On: 09/23/2020
Operating Permit Renewal Date: 02/20/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation

7018521194

Operator Contact: Calvin Wilson;Jason Shanley

Owner/Operator: Parkland USA Corporation

Calvin Wilson, UST Class A Operator
Calvin Wilson, UST Class B Global Operator
Jason Shanley, UST Class A Operator
Jason Shanley, UST Class B Operator
Kelley Phipps, UST Class B Operator
Kristy Saul, UST Class B Operator
Mari Cordova, UST Class B Operator

Tank Code	05	Tank Age	29	Tank Installed Date	11/19/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4492	Spill Test Date	09/23/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	29	Tank Installed Date	11/19/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4493	Spill Test Date	09/23/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	03/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	29	Tank Installed Date	11/19/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4494	Spill Test Date	09/23/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	03/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	29	Tank Installed Date	11/19/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4495	Spill Test Date	09/23/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	29	Tank Installed Date	11/19/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4496	Spill Test Date	09/23/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/09/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/09/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	03/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of Manhattan

Location:	DANHOF CHEVROLET INC 6605 Amsterdam Rd Manhattan, MT 59741-8315 Gallatin	Facility Code:	21153
		Last Inspected On:	04/12/2021
		Operating Permit Renewal Date:	04/16/2024
		System Facility ID:	16-01367

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Danhof Chevrolet Inc4062827231

Operator Contact: Jason Rorabaugh;Rocky Mountain Supply Inc Belgrade4063884008

Owner/Operator: Danhof Chevrolet Inc

Dennis Franks, UST Class B Global Operator
Jason Rorabaugh, UST Class A Operator

Tank Code	09	Tank Age	36	Tank Installed Date	06/13/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	800	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/12/2021	Sump Tightness Test Date	04/12/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/12/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	08/10/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	10	Tank Age	36	Tank Installed Date	06/13/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	801	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/12/2021	Sump Tightness Test Date	04/12/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/12/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	08/10/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	11	Tank Age	36	Tank Installed Date	06/13/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	802	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/12/2021	Sump Tightness Test Date	04/12/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/12/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	08/10/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of Manhattan

Location: HARLOWS SCHOOL BUS SVC
1085 Yadon Rd
Manhattan, MT 59741 Gallatin

System Facility ID:56-13969

Facility Code: 30631
Last Inspected On: 01/21/2020
Operating Permit Renewal Date: 03/03/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: HJJ Properties LLC 7012241767

Operator Contact:

Owner/Operator: HJJ Properties LLC

Tank Code	01	Tank Age	23	Tank Installed Date	12/30/1999	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4142	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	23	Tank Installed Date	12/30/1999	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4143	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Gallatin County in the City of Manhattan

Location: SCHUTTER SEED FARM, INC
3627 Wooden Shoe Rd
Manhattan, MT 59741-8108 Gallatin

System Facility ID:16-10184

Facility Code: 21567
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/26/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sid Schutter Farm Inc

Operator Contact:	Sid Schutter	4062846478
-------------------	--------------	------------

Owner/Operator: Sid Schutter Farm Inc

Sid Schutter, UST Class A Operator

Sid Schutter, UST Class B Operator

Tank Code	S6	Tank Age	38	Tank Installed Date	01/31/1984	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Deregulated under SB386	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	28	Tank Installed Date	01/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1909	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/11/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	28	Tank Installed Date	01/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1910	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/11/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	--------------------	--	--	----------	--	--	--	--	--

Facility Summary in Gallatin County in the City of Manhattan

Location: THRIFTWAY SUPER STOP 12
404 S Broadway St
Manhattan, MT 59741 Gallatin

System Facility ID:16-03431

Facility Code: 21242
Last Inspected On: 04/27/2022
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Sutey Oil Co Inc	4064942305
-------------------------	------------------	------------

Operator Contact:	Bryan Kelsey;Louis Sutey	4064915808
-------------------	--------------------------	------------

Owner/Operator:	Sutey Oil Co Inc
	Bryan Kelsey, UST Class A Operator
	Bryan Kelsey, UST Class B Operator
	Louis Sutey, UST Class A Operator
	Louis Sutey, UST Class B Global Operator
	Tanya West, UST Class B Operator

Tank Code	07	Tank Age	15	Tank Installed Date	12/04/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5124	Spill Test Date	04/27/2022	Piping Installed Date	04/09/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	04/27/2022	Line Tightness Test Date	03/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/27/2022			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	25	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	809	Spill Test Date	04/27/2022	Piping Installed Date	04/09/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	04/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	04/27/2022	Line Tightness Test Date	03/03/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/27/2022			ATG Type	/8484 Series PLLD;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	25	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	810	Spill Test Date	04/27/2022	Piping Installed Date	05/26/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/20/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	04/27/2022	Line Tightness Test Date	03/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	04/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	25	Tank Installed Date	05/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	811	Spill Test Date	04/27/2022	Piping Installed Date	04/09/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	04/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/27/2022	Line Tightness Test Date	03/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of Three Forks

Location: THRIFTWAY CONOCO 15
5 S Main St
Three Forks, MT 59752 Gallatin

System Facility ID:16-00987

Facility Code: 21128
Last Inspected On: 02/03/2022
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Sutey;Sutey Oil Co Inc4064942305

Operator Contact: Bryan Kelsey;Louis Sutey4064915808

Owner/Operator: David Sutey

Owner/Operator: Sutey Oil Co Inc

Bryan Kelsey, UST Class A Operator
Bryan Kelsey, UST Class B Operator
Dave Stine, UST Class B Operator
Gayle Ross, UST Class B Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator

Tank Code	07	Tank Age	28	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	520	Spill Test Date	04/29/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	28	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	521	Spill Test Date	04/29/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	Yes
Capacity	3000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	28	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	522	Spill Test Date	04/29/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	3000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	28	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	523	Spill Test Date	04/29/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	28	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	524	Spill Test Date	04/29/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	12	Tank Age	28	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	525	Spill Test Date	04/29/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	13	Tank Age	28	Tank Installed Date	04/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	526	Spill Test Date	04/29/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/01/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	02/01/2022	Line Tightness Test Date	02/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Gallatin County in the City of Three Forks

Location: WHEAT MONTANA FARMS INC
10778 US Hwy 287
Three Forks, MT 59752-9518 Gallatin

System Facility ID:56-14009

Facility Code: 30669
Last Inspected On: 04/20/2022
Operating Permit Renewal Date: 07/07/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wheat Montana Bakery Inc

Operator Contact: Eric Wilson;Wheat Montana Bakery Inc;Peter Carlson;Wayne Fuller;Wayner Fuller;Wheat Montana Bakery Inc4065824575

Owner/Operator: Wheat Montana Bakery Inc

Eric Wilson, UST Class A Operator
Eric Wilson, UST Class B Global Operator
Peter Carlson, UST Class A Operator
Wayne Fuller, UST Class A Operator
Wayner Fuller, UST Class A Operator

Tank Code	01	Tank Age	21	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4384	Spill Test Date	04/20/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/03/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/20/2022	Line Tightness Test Date	02/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	21	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4385	Spill Test Date	05/02/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/03/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/20/2022	Line Tightness Test Date	02/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	21	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	4386	Spill Test Date	04/20/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/03/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/20/2022	Line Tightness Test Date	02/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/20/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: CORNER CENEX
136 N Canyon St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-00055

Facility Code: 21097
Last Inspected On: 05/04/2020
Operating Permit Renewal Date: 09/05/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Brad Schmier;Jerrys Enterprises Inc

Owner/Operator: Brad Schmier

Owner/Operator: Jerrys Enterprises Inc

Brad Schmier, UST Class A Operator
Brad Schmier, UST Class B Operator
Timothy Heideman, UST Class A Operator
Timothy Heideman, UST Class B Operator

Tank Code	10	Tank Age	31	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2263	Spill Test Date	05/04/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/04/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/04/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				
Tank Code	11	Tank Age	31	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2264	Spill Test Date	05/04/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/04/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/04/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				
Tank Code	12	Tank Age	31	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2265	Spill Test Date	05/04/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/04/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/04/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				
Tank Code	13	Tank Age	31	Tank Installed Date	10/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2266	Spill Test Date	05/04/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/04/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	05/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/04/2020			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: DELAWARE NORTH PARKS SERVICES AT YELLOWSTONE LLC
251 Echo Canyon Rd
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-06367

Facility Code: 21389
Last Inspected On: 06/29/2022
Operating Permit Renewal Date: 10/01/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Delaware North Companies Inc7168585000

Operator Contact: Jesse Spears;Karmon Bryant4065482709

Owner/Operator: Delaware North Companies Inc

Jesse Spears, UST Class A Operator
Jesse Spears, UST Class B Global Operator
Karmon Bryant, UST Class A Operator
Karmon Bryant, UST Class B Global Operator

Tank Code	S4	Tank Age	41	Tank Installed Date	05/01/1981	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No

Tank Status	Deregulated under SB386	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Inventory Reconciliation;Tank Tightness Testing	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1277	Spill Test Date	05/18/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/25/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Veeder Root/Red Jacket FXIV				
Tank Code	06	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1278	Spill Test Date	05/18/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/25/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	05/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Veeder Root/Red Jacket FXIV				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: DNC PARKS AND RESORTS AT YELLOWSTONE
ADVENTURES
415 Yellowstone Ave
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-11619

Facility Code: 21712
Last Inspected On: 05/17/2021
Operating Permit Renewal Date: 10/19/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Delaware North Companies Inc 7168585000

Operator Contact: David Singleton;Erik Dawkins;Holly Loomans;Kennedy Brown;Ron Wilkes 4065488440;4065995991

Owner/Operator: Delaware North Companies Inc

Alexandra Chipouras, UST Class B Operator
David Singleton, UST Class A Operator
David Singleton, UST Class B Global Operator
Erik Dawkins, UST Class A Operator
Erik Dawkins, UST Class B Global Operator
Erik Dawkins, UST Class B Operator
Holly Loomans, UST Class A Operator
Holly Loomans, UST Class B Operator
Justin Cook, UST Class B Global Operator
Justin Cook, UST Class B Operator
Kennedy Brown, UST Class A Operator
Kennedy Brown, UST Class B Operator
Ron Wilkes, UST Class A Operator

Tank Code	02	Tank Age	29	Tank Installed Date	10/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2350	Spill Test Date	05/17/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	05/17/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: DNC PARKS AND RESORTS OF WEST YELLOWSTONE
315 Yellowstone Ave
West Yellowstone, MT 59758-9527 Gallatin

Facility Code: 21831
Last Inspected On: 05/17/2021
System Facility ID:16-13528
Operating Permit Renewal Date: 05/17/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Delaware North Companies Inc	7168585000
Operator Contact:	Cedar Shannon;DNC Parks & Resorts of West Yellowstone Inc;Jason Fatouros;Karmon Bryant	4062200463;4062230843;7168585055;4065482709

Owner/Operator: Delaware North Companies Inc

Cedar Shannon, UST Class A Operator
Cedar Shannon, UST Class B Operator
Jason Fatouros, UST Class A Operator
Jason Fatouros, UST Class B Global Operator
Jerry Rutan, UST Class B Operator
Karmon Bryant, UST Class A Operator
Karmon Bryant, UST Class B Global Operator

Tank Code	01	Tank Age	28	Tank Installed Date	09/10/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2306	Spill Test Date	10/19/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/19/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/17/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	05/17/2021	Line Tightness Test Date	10/19/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: EAGLE CHEVRON 1
3 Canyon St
West Yellowstone, MT 59758-9515 Gallatin

Facility Code: 21495
Last Inspected On: 05/06/2020
System Facility ID:16-08570
Operating Permit Renewal Date: 10/08/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Eagle Store Holding Company LLC	7864864370
-------------------------	---------------------------------	------------

Owner/Operator: Eagle Store Holding Company LLC

Doreena Ford, UST Class B Operator
Moshe Korleicar, UST Class A Operator
Moshe Korleicar, UST Class B Operator

Tank Code	06	Tank Age	33	Tank Installed Date	04/28/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3986	Spill Test Date	05/06/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2020			ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	33	Tank Installed Date	04/28/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3987	Spill Test Date	05/06/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2020			ATG Type	Veeder Root/TLS-300				
Tank Code	08	Tank Age	25	Tank Installed Date	10/20/1997	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	843	Spill Test Date	05/06/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/06/2020			ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: EAGLE CHEVRON 2
17 Canyon St
West Yellowstone, MT 59758 Gallatin

Facility Code: 21496
Last Inspected On: 05/06/2020
System Facility ID:16-08571
Operating Permit Renewal Date: 10/08/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Eagle Store Holding Company LLC7864864370

Operator Contact: Eva Eagle;Moshe Korleicar9548811418

Owner/Operator: Eagle Store Holding Company LLC

Doreena Ford, UST Class B Operator
Eva Eagle, UST Class A Operator
Lee Sloan, UST Class B Operator
Moshe Korleicar, UST Class A Operator
Moshe Korleicar, UST Class B Operator

Tank Code	07	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4018	Spill Test Date	05/06/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	08	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4019	Spill Test Date	05/06/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	32	Tank Installed Date	10/05/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	844	Spill Test Date	05/06/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	32	Tank Installed Date	10/05/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	845	Spill Test Date	05/06/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/06/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: ECONO MART
307 Firehole Ave
West Yellowstone, MT 59758-9516 Gallatin

System Facility ID:16-10356

Facility Code: 21581
Last Inspected On: 10/06/2020
Operating Permit Renewal Date: 03/03/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Econo Clyde G Seely;Firehole Holdings LLC4066467887

Operator Contact: Merrick Young

Owner/Operator: Econo Clyde G Seely

Owner/Operator: Firehole Holdings LLC

Merrick Young, UST Class A Operator
Merrick Young, UST Class B Global Operator

Tank Code	06	Tank Age	21	Tank Installed Date	10/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
-----------	----	----------	----	---------------------	------------	---------------	------------	-----------------	------------------	----------------	--------------------------------

Tag Number	4438	Spill Test Date	05/04/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/06/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/05/2021			ATG Type	Veeder Root/TLS-300				
Tank Code	01	Tank Age	47	Tank Installed Date	02/11/1975	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	847	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/06/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/02/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/05/2021			ATG Type	Veeder Root/TLS-300				
Tank Code	02	Tank Age	47	Tank Installed Date	02/11/1975	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	848	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/06/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/02/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/05/2021			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	47	Tank Installed Date	02/11/1975	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	850	Spill Test Date	05/04/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	10/06/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/02/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/05/2021			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	47	Tank Installed Date	02/11/1975	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	851	Spill Test Date		Piping Installed Date	05/16/2013	Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/06/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/02/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	10/05/2021			ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: KIRKWOOD RANCH MOTEL TRAILER PARK
35 Kirkwood Creek Rd
West Yellowstone, MT 59758-9770 Gallatin

System Facility ID:16-10793

Facility Code: 21623
Last Inspected On: 04/24/2020
Operating Permit Renewal Date: 05/25/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: E I Holdings LLC8019166605

Operator Contact: Chris Swenson;Kyle Burden4064901927

Owner/Operator: E I Holdings LLC

Chris Swenson, UST Class A Operator
Chris Swenson, UST Class B Global Operator
Kyle Burden, UST Class A Operator
Kyle Burden, UST Class B Operator

Tank Code	05	Tank Age	22	Tank Installed Date	08/01/2000	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
-----------	----	----------	----	---------------------	------------	---------------	------------------------------	-----------------	------------------	----------------	---------------

Tag Number	4237	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/29/2020	Sump Tightness Test Date	04/24/2020	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/24/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	04/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/Red Jacket FXIV;Veeder Root/TLS-300				
Tank Code	06	Tank Age	22	Tank Installed Date	08/01/2000	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4580	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/29/2020	Sump Tightness Test Date	04/24/2020	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/24/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	04/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/Red Jacket FXIV;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: LIONSHEAD RESORT
1545 Targhee Pass Hwy
West Yellowstone, MT 59758-9626 Gallatin

System Facility ID:16-12923

Facility Code: 21802
Last Inspected On: 05/18/2021
Operating Permit Renewal Date: 05/18/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Yellowstone Rental Properties LLC Billings 4066467606

Operator Contact:

Owner/Operator: Yellowstone Rental Properties LLC Billings

Tank Code	02	Tank Age	30	Tank Installed Date	11/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3391	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/18/2021	Primary Tank Leak Detection	Vapor Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Gallatin County in the City of West Yellowstone

Location: RIVERSIDE STATION
215 N Canyon St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-04500

Facility Code: 21290
Last Inspected On: 05/04/2020
Operating Permit Renewal Date: 08/02/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jerrys Enterprises Inc

Operator Contact: Brad Schmier

Owner/Operator: Jerrys Enterprises Inc

Brad Schmier, UST Class A Operator

Tank Code	05	Tank Age	23	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3684	Spill Test Date	05/04/2020	Piping Installed Date	09/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	11/05/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	23	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3685	Spill Test Date	05/04/2020	Piping Installed Date	09/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	04/29/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	23	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3686	Spill Test Date	05/04/2020	Piping Installed Date	09/12/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/04/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	04/29/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: SUPER SAVE CONOCO
138 Firehole Ln
West Yellowstone, MT 59758-9609 Gallatin

System Facility ID:16-04501

Facility Code: 21291
Last Inspected On: 05/05/2020
Operating Permit Renewal Date: 08/02/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Jerrys Enterprises Inc

Operator Contact: Brad Schmier

Owner/Operator: Jerrys Enterprises Inc

Brad Schmier, UST Class A Operator
Brad Schmier, UST Class B Operator

Tank Code	05	Tank Age	33	Tank Installed Date	12/11/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1414	Spill Test Date	05/05/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/07/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	07	Tank Age	33	Tank Installed Date	12/11/1989	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1416	Spill Test Date	05/05/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	10/07/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				
Tank Code	08	Tank Age	28	Tank Installed Date	06/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1417	Spill Test Date	05/05/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/05/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/05/2020			ATG Type	Veeder Root/Red Jacket FX1;Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: TRAVELERS SERVICE CENTER
26 Electric St
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-09852

Facility Code: 21535
Last Inspected On: 05/05/2020
Operating Permit Renewal Date: 08/06/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Loomis Enterprises Inc4066467773

Operator Contact: Bradley Loomis4066467773

Owner/Operator: Loomis Enterprises Inc

Bradley Loomis, UST Class A Operator
Bradley Loomis, UST Class B Operator

Tank Code	04	Tank Age	24	Tank Installed Date	04/21/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1555	Spill Test Date	05/05/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/05/2020			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	24	Tank Installed Date	04/21/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1556	Spill Test Date	05/05/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/05/2020			ATG Type	Veeder Root/TLS-300				
Tank Code	06	Tank Age	24	Tank Installed Date	04/21/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1557	Spill Test Date	05/05/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/08/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	10/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/05/2020			ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: TWO TOP SNOWMOBILE RENTAL
645 Gibbon Ave
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-04445

Facility Code: 21289
Last Inspected On: 01/12/2021
Operating Permit Renewal Date: 02/27/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	DNC Parks & Resorts Yellowstone Adventures Inc.	4065867593
Operator Contact:	Jennie Allen;Kennedy Brown	

Owner/Operator: DNC Parks & Resorts Yellowstone Adventures Inc.
Jennie Allen, UST Class A Operator
Jennie Allen, UST Class B Operator
Kennedy Brown, UST Class A Operator
Kennedy Brown, UST Class B Operator

Tank Code	01	Tank Age	30	Tank Installed Date	09/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1598	Spill Test Date	10/19/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/12/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/19/2021			ATG Type	Veeder Root/TLS-300				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: WEST ENTRANCE BLDG 458
W Entrance Bldg 458
West Yellowstone, MT 59758 Gallatin

System Facility ID:16-08870

Facility Code: 21515
Last Inspected On: 07/13/2022
Operating Permit Renewal Date: 09/13/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	National Park Service Mammoth	3073442333
-------------------------	-------------------------------	------------

Owner/Operator: National Park Service Mammoth

Claude Long, UST Class A Operator
Harry Laney, UST Class A Operator
Harry Laney, UST Class B Operator
Jason Ogle, UST Class A Operator
Nathan Munson, UST Class A Operator

Tank Code	01	Tank Age	34	Tank Installed Date	08/24/1988	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1739	Spill Test Date	08/23/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	PVC	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/14/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	08/23/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2021			ATG Type	OPW / EMCO/Other				

Tank Code	02	Tank Age	34	Tank Installed Date	08/24/1988	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1740	Spill Test Date	08/23/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	PVC	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/14/2022	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	08/23/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/23/2021			ATG Type	OPW / EMCO/Other				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: WESTGATE STATION
11 Yellowstone Ave
West Yellowstone, MT 59758-9510 Gallatin

Facility Code: 21256
Last Inspected On: 10/07/2020
Operating Permit Renewal Date: 01/14/2024

System Facility ID:16-03734

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner/Operator: Westgate Station West Yellowstone

Cole Parker, UST Class A Operator

Cole Parker, UST Class B Operator

Tank Code	09	Tank Age	24	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3108	Spill Test Date	10/07/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	24	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3109	Spill Test Date	10/07/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	24	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3110	Spill Test Date	10/07/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	10/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	10/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	24	Tank Installed Date	10/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	3111	Spill Test Date	10/07/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	10/07/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	10/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Gallatin County in the City of West Yellowstone

Location: YELLOWSTONE ARCTIC YAMAHA ELECTRIC ST
208 Electric St
West Yellowstone, MT 59758 Gallatin

Facility Code: 21583
Last Inspected On: 07/30/2021
System Facility ID:16-10358
Operating Permit Renewal Date: 10/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Firehole Holdings LLC4066467887

Operator Contact: Merrick Young

Owner/Operator: Firehole Holdings LLC

Merrick Young, UST Class A Operator
Merrick Young, UST Class B Operator

Tank Code	02	Tank Age	30	Tank Installed Date	09/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	2305	Spill Test Date	05/05/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/02/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	05/05/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	05/05/2021			ATG Type	Veeder Root/TLS-300				
--	--	--------------------	------------	--	--	----------	---------------------	--	--	--	--

Facility Summary in Gallatin County in the City of West Yellowstone

Location: YELLOWSTONE HOLIDAY RESORT 16990 Hebgen Lake Rd West Yellowstone, MT 59758 Gallatin			System Facility ID:16-11066		Facility Code: 21649 Last Inspected On: 10/05/2021 Operating Permit Renewal Date: 03/09/2025	
Note: Inspection is due 90 days before the Operating Permit Renewal Date.						

Owner Operator Contact:	Grayling Partners LC										
-------------------------	----------------------	--	--	--	--	--	--	--	--	--	--

Operator Contact:	Bradley Campbell;Todd Barta					4065392394;4065701364					
-------------------	-----------------------------	--	--	--	--	-----------------------	--	--	--	--	--

Owner/Operator:	Grayling Partners LC										
-----------------	----------------------	--	--	--	--	--	--	--	--	--	--

Bradley Campbell, UST Class A Operator
James Hynes, UST Class B Operator
Todd Barta, UST Class A Operator
Vickie Barta, UST Class B Operator

Tank Code	S6	Tank Age	23	Tank Installed Date	10/01/1999	Tank Material	Concrete	Piping Material	Fiberglass	Overfill Types	
Tag Number	4132	Spill Test Date		Piping Installed Date	05/03/2013	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	04/27/2022	Sump Tightness Test Date	10/05/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	1500	ATG Test Date		Line Tightness Test Date	04/27/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/Red Jacket FXIV				